ATTESTATION OF CONFORMITY

Issued to	:	Omnik New Energy Co., Ltd. XingHu St. No.218, bioBAY Park A4-314, Suzhou, Jiangsu, China
For the product	:	Grid-connected PV Inverter
Trademark	:	OMNIK Omnik New Energy
Type/Model	:	Omniksol-1k-TL2-M, Omniksol-1.5k-TL2-M
Ratings	:	Omniksol-1k-TL2-M Input: max 500 Vdc, MPPT voltage range: 60-400 Vdc, max 10 A Output: 230 Vac, 50 Hz, 1000 VA, max 5 A Omniksol-1.5k-TL2-M Input: max 500 Vdc, MPPT voltage range: 60-400 Vdc, max 10 A Output: 230 Vac, 50 Hz, 1500 VA, max 7,5 A
Manufactured by	:	Omnik New Energy Co., Ltd. Weixin Road No.63, SIP, Suzhou, Jiangsu, China
Requirements	:	UTE C 15-712-1:2010-07, Rec 0:2010-09, Rec 1:2012-02 DIN VDE V 0126-1-1/A1:2012-02 ERDF-NOI-RES_13E:2013-06

This Attestation is granted on account of an examination by DEKRA, the results of which are laid down in a confidential file no. 6004810.51

The examination has been carried out on one single specimen of the product, submitted by the manufacturer. The Attestation does not include an assessment of the manufacturer's production. Conformity of his production with the specimen tested by DEKRA is not the responsibility of DEKRA.

Shanghai, 11 April 2017 Number: 6004810.02AOC

DEKRA Testing and Certification (Shanghai) Ltd.

Kreny Lin
Certification Manager

© Integral publication of this attestation and adjoining reports is allowed.

DEKRA Testing and Certification (Shanghai) Ltd.
3F #250 Jiangchangsan Road Building 16 Headquarter Economy Park Shibei Hi-Tech Park, Zhabei District Shanghai 200436 China
T +86 21 6056 7666 F +86 21 6056 7555 www.dekra-certification.com