



A P P R O V A L S ®

Certificate of Approval

Addendum

Certificate No.: SAA121924

Date of Issue: 25 September 2012

Class Description: Non-Declared
Product Description: Grid-connected PV Inverter

Additional Models

Omniksol-17k-TL

Omniksol-13k-TL

Description

Similar to Omniksol-20k-TL except rated input MPP: 440-850Vdc and output 17000W, Max 26A.


Similar to Omniksol-20k-TL except rated input MPP: 400-850Vdc, 22A+11A and output 13000W, Max 20A.

A handwritten signature in dark ink, appearing to read 'Gina', positioned above a horizontal line.

For and on Behalf of
SAA Approvals Pty Ltd

SAA Approvals Pty Ltd Electrical Product Safety Certification Scheme as accredited by JAS-ANZ under ISO/IEC Guide 65 certifies that the electrical product described on this certificate complies with the minimum electrical safety requirements for which the application has been made.

JAS-ANZ



121924/2