



LCIE

BV LCIE
CHINA
Number

N° 1566AS05OMK16953

ATTESTATION of conformity with European Directives



Product: **Grid-tied photovoltaic inverter**
Reference **Omniksol-13k-TL, Omniksol-17k-TL, Omniksol-20k-TL**
Issued to **Omnik New Energy Co., Ltd.**
Address **Xinghu Road No.218 bioBAY Park A4-314,215123 Suzhou, China**
Manufacturer **Omnik New Energy Co., Ltd.**
Technical characteristics **See Next Page**

The submitted sample of the above equipment has been tested for  marking according to following European Directive and following standards:

- Low voltage directive 2006/95/EC

Standards	Report number	Report date
EN 62109-1:2010	OMK-15MA2113FTSP-1	07/05/2015
EN 62109-2:2011	OMK-15MA2113FTSP-2	07/05/2015

The referred test report(s) show that the product complies with standard(s) recognized as giving presumption of compliance with the essential requirements in the specified European Directive

This verification does not imply assessment of the production of the product
The  marking may be affixed if all relevant and effective European Directives with  are applicable

Shanghai (P.R. China), May 12th, 2015



This document shall not be reproduced, except in full, without the written approval of BV LCIE China.
Information given in this document, are related to the tested specimen of the described electrical sample.

LCIE CHINA
上海欧亚电气技术咨询服务有限公司

Building 4, No. 518, Xin Zhuan Road, CaoHejing
Songjiang High-Tech Park, Shanghai P.R.C
(201612)

Tel: +86 21 6195 7000
Fax: +86 21 6195 7001
Email: contact@cn.bureauveritas.com



LCIE

BV LCIE
CHINA
Number

N°1566AS05OMK16953

Model / Type.....	Omniksol-13k-TL	Omniksol-17k-TL	Omniksol-20k-TL
MPP DC voltage range [V].....:	400-850Vdc	440-850Vdc	480-850Vdc
Input DC voltage range [V].....:	220-1000Vdc	220V-1000Vdc	220V-1000Vdc
Input DC current [A].....:	22/11A	22/22A	
Output AC voltage [V].....:	230/400Vac, 3/N/PE, 50Hz		
Output AC current [A].....:	Nom. 18,8A, Max. 20A	Nom. 24,6A, Max. 26A	Nom. 28A, Max. 29A
Output power [W].....:	13000W	17000W	19200W

Holger SCHAEFFER
Certification Manager



This document shall not be reproduced, except in full, without the written approval of BV LCIE China.
Information given in this document, are related to the tested specimen of the described electrical sample.

LCIE CHINA
上海欧亚电气技术咨询服务有限公司

Building 4, No. 518, Xin Zhuan Road, CaoHejing
Songjiang High-Tech Park, Shanghai P.R.C
(201612)

Tel: +86 21 6195 7000
Fax: +86 21 6195 7001
Email: contact@cn.bureauveritas.com