

ATTESTATION OF CONFORMITY

Issued to : Omnik New Energy Co., Ltd.
Weixin Road No.63, SIP, Suzhou, Jiangsu, China

For the product : Grid-connected PV Inverter

Trademark : 

Type/Model : Omniksol-4k-TL2-TH, Omniksol-5k-TL2-TH, Omniksol-6k-TL2-TH

Ratings : Omniksol-4k-TL2-TH
Input: max 1000 Vdc, MPPT voltage range: 150-800 Vdc, max 11/11 A,
I_{SC} PV: 16/16 A
Output: 3N~, 230/400 V, 50 Hz, 4000 VA, max 6,1 A
Omniksol-5k-TL2-TH
Input: max 1000 Vdc, MPPT voltage range: 150-800 Vdc, max 11/11 A,
I_{SC} PV: 16/16 A
Output: 3N~, 230/400 V, 50 Hz, 5000 VA, max 7,6 A
Omniksol-6k-TL2-TH
Input: max 1000 Vdc, MPPT voltage range: 150-800 Vdc, max 11/11 A,
I_{SC} PV: 16/16 A
Output: 3N~, 230/400 V, 50 Hz, 6000 VA, max 9,2 A

Manufactured by : Omnik New Energy Co., Ltd.
Weixin Road No.63, SIP, Suzhou, Jiangsu, China

Requirements : IEC 61683:1999
IEC 61727:2004
IEC 62116:2014
IEC 60068-2-1:2007
IEC 60068-2-2:2007
IEC 60068-2-14:2009
IEC 60068-2-30:2005
IEC 60529:1989+A1:1999

This Attestation is granted on account of an examination by DEKRA, the results of which are laid down in a confidential file no. 6007242.50(A-E)
The examination has been carried out on one single specimen of the product, submitted by the manufacturer.
The Attestation does not include an assessment of the manufacturer's production. Conformity of his production with the specimen tested by DEKRA is not the responsibility of DEKRA

Shanghai, 31 August 2017 Number: 6007242.01AOC

DEKRA Testing and Certification (Shanghai) Ltd.

Kreny Lin
Certification Manager

© Integral publication of this attestation and adjoining reports is allowed.