

ATTESTATION OF CONFORMITY

Issued to: Omnik New Energy Co., Ltd.
Weixin Road No.63, SIP, Suzhou, Jiangsu, China

For the product: Grid-Connected PV Inverter

Trade name: 
Omnik New Energy

Type/Model: Omniksol-2k-TL3-S, Omniksol-2.5k-TL3-S, Omniksol-3k-TL3-S

Ratings: Omniksol-2k-TL3-S
Input: max 500 Vdc, MPPT voltage range: 120-450 Vdc, max 10 A, Isc PV: 14A
Output: 230 Vac, 50 Hz, nominal 2000 W, max 2200 VA, nominal 9A, max 10 A
Omniksol-2.5k-TL3-S
Input: max 500 Vdc, MPPT voltage range: 120-450 Vdc, max 10 A, Isc PV: 14A
Output: 230 Vac, 50 Hz, nominal 2500 W, max 2750 VA, nominal 11 A, max 12,5 A
Omniksol-3k-TL3-S
Input: max 550 Vdc, MPPT voltage range: 120-500 Vdc, max 10 A, Isc PV: 14A
Output: 230 Vac, 50 Hz, nominal 3000 W, max 3300 VA, nominal 13 A, max 15 A

Manufactured by: Omnik New Energy Co., Ltd.
Weixin Road No.63, SIP, Suzhou, Jiangsu, China

Requirements: EN 50438:2013 with deviations according the national network and system protection for the Netherlands

This Attestation is granted on account of an examination by DEKRA, the results of which are laid down in test report no. 6008079.51

The examination has been carried out on one single specimen of the product, submitted by the manufacturer.

The Attestation does not include an assessment of the manufacturer's production. Conformity of his production with the specimen tested by DEKRA is not the responsibility of DEKRA.

Shanghai, 21 November 2017

Number: 6008079.01AOC

DEKRA Testing and Certification (Shanghai) Ltd.


Kreny Lin
Certification Manager

© Integral publication of this attestation and adjoining reports is allowed

DEKRA Testing and Certification (Shanghai) Ltd.

3F #250 Jiangchangsan Road Building 16 Headquarter Economy Park Shibe Hi-Tech Park, Zhabei District Shanghai 200436 China
T +86 21 6056 7666 F +86 21 6056 7555 www.dekra-certification.com