

IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT  
(IECEE) CB SCHEME

CB TEST CERTIFICATE

Product	Grid-connected PV inverter
Name and address of the applicant	Omnik New Energy Co., Ltd. Weixin Road No.63, SIP, Suzhou, Jiangsu, China
Name and address of the manufacturer	Omnik New Energy Co., Ltd. Weixin Road No.63, SIP, Suzhou, Jiangsu, China
Name and address of the factory	<input type="checkbox"/> Additional information on page 2 Omnik New Energy Co., Ltd. Weixin Road No.63, SIP, Suzhou, Jiangsu, China
Note: When more than one factory, please report on page 2	
Ratings and principal characteristics	Omniksol-3k-TL3 Input: max 580 Vdc, MPPT voltage range: 120-500 Vdc, max 10/10 A, Isc PV: 14 /14 A Output: 230 Vac, 50/60 Hz, nominal 3000 W, max 3300 VA, nominal 13 A, max 15 A Omniksol-3.68k-TL3 Input: max 580 Vdc, MPPT voltage range: 120-500 Vdc, max 10/10 A, Isc PV: 14 /14 A Output: 230 Vac, 50/60 Hz, nominal 3680 W, max 3680 VA, nominal 16 A, max 16 A Omniksol-4k-TL3 Input: max 580 Vdc, MPPT voltage range: 120-500 Vdc, max 10/10 A, Isc PV: 14 /14 A Output: 230 Vac, 50/60 Hz, nominal 4000 W, max 4400 VA, nominal 17.4 A, max 20 A
Trademark (if any)	
Customer's Testing Facility (CTF) Stage used	
Model / Type Ref.	Omniksol-3k-TL3, Omniksol-3.68k-TL3, Omniksol-4k-TL3
Additional information (if necessary may also be reported on page 2)	<input type="checkbox"/> Additional information on page 2
A sample of the product was tested and found to be in conformity with	IEC 62109-1:2010, IEC 62109-2:2011
As shown in the Test Report Ref. No. which forms part of this Certificate	6028354.50(A-B)

This CB Test Certificate is issued by the National Certification Body

DEKRA Certification B.V.  
Meander 1051, NL-6825 MJ Arnhem, Netherlands

