

IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT
(IECEE) CB SCHEME

CB TEST CERTIFICATE

Product	Grid-connected PV inverter
Name and address of the applicant	Omnik New Energy Co., Ltd. Weixin Road No.63, SIP, Suzhou, Jiangsu China
Name and address of the manufacturer	Omnik New Energy Co., Ltd. Weixin Road No.63, SIP, Suzhou, Jiangsu China
Name and address of the factory	<input type="checkbox"/> Additional information on page 2 Omnik New Energy Co., Ltd. Weixin Road No.63, SIP, Suzhou, Jiangsu China
<i>Note: When more than one factory, please report on page 2</i>	
Ratings and principal characteristics	Omniksol-2k-TL3-S Input: max 500 Vdc, MPPT voltage range: 120-450 Vdc, max 10 A, Isc PV: 14A Output: 230 Vac, 50/60 Hz, nominal 2000 W, max 2200 VA, nominal 9A, max 10 A Omniksol-2.5k-TL3-S Input: max 500 Vdc, MPPT voltage range: 120-450 Vdc, max 10 A, Isc PV: 14A Output: 230 Vac, 50/60 Hz, nominal 2500 W, max 2750 VA, nominal 11 A, max 12,5 A Omniksol-3k-TL3-S Input: max 550 Vdc, MPPT voltage range: 120-500 Vdc, max 10 A, Isc PV: 14A Output: 230 Vac, 50/60 Hz, nominal 3000 W, max 3300 VA, nominal 13 A, max 15 A
Trademark (if any)	
Customer's Testing Facility (CTF) Stage used	
Model / Type Ref.	Omniksol-2k-TL3-S, Omniksol-2.5k-TL3-S, Omniksol-3k-TL3-S
Additional information (if necessary may also be reported on page 2)	<input type="checkbox"/> Additional information on page 2
A sample of the product was tested and found to be in conformity with	IEC 62109-1:2010, IEC 62109-2:2011
As shown in the Test Report Ref. No. which forms part of this Certificate	6008079.50 (A-B)

This CB Test Certificate is issued by the National Certification Body

DEKRA Certification B.V.
Meander 1051, NL-6825 MJ Arnhem, Netherlands

