

# ATTESTATION OF CONFORMITY

Issued to: Omnik New Energy Co., Ltd.  
Weixin Road No.63, SIP, Suzhou, Jiangsu, China

For the product: Grid-Connected PV Inverter

Trade name:  Omnik New Energy

Type/Model: Omniksol-13k-TL3, Omniksol-10k-TL3

Ratings: Omniksol-13k-TL3  
Input: max 1000 Vdc, MPPT voltage range: 150-800 Vdc, max 20/10 A, I<sub>sc</sub> PV: 24/12A  
Output: 3/N/PE, 230/400 Vac, 50/60Hz, nominal 13000 W, max 13000 VA, max 22 A

Omniksol-10k-TL3  
Input: max 1000 Vdc, MPPT voltage range: 150-800 Vdc, max 10/10 A, I<sub>sc</sub> PV: 12/12A  
Output: 3/N/PE, 230/400 Vac, 50/60Hz, nominal 10000 W, max 10000 VA, max 17 A

Manufactured by: Omnik New Energy Co., Ltd.  
Weixin Road No.63, SIP, Suzhou, Jiangsu, China

Requirements: EN 62109-1:2010  
EN 62109-2:2011

This Attestation is granted on account of an examination by DEKRA, the results of which are laid down in test report no. 6018354.50(A-B)

This Attestation implies that the examined types are in accordance with the standards designated under the Low voltage directive (LVD) 2014/35/EU.

The examination has been carried out on one single specimen of the product, submitted by the manufacturer.

The Attestation does not include an assessment of the manufacturer's production. Conformity of his production with the specimen tested by DEKRA is not the responsibility of DEKRA.

Shanghai, 9 March 2018

Number: 6018354.02AOC

DEKRA Testing and Certification (Shanghai) Ltd.

  
Kreny Lin  
Certification Manager

© Integral publication of this attestation and adjoining reports is allowed

The CE marking may be affixed on the product if all relevant and effective EC directives are complied with



DEKRA Testing and Certification (Shanghai) Ltd.

3F #250 Jiangchangsan Road Building 16 Headquarter Economy Park Shibe Hi-Tech Park, Zhabei District Shanghai 200436 China  
T +86 21 6056 7666 F +86 21 6056 7555 www.dekra-certification.com