

**Suzhou Headquarter**

No.63 Weixin Road, SIP, 215122 Suzhou China

Tel:+86 512 6956 8216

Email:[info@omnik-solar.com](mailto:info@omnik-solar.com)

## Manufacture Declaration for EN50438:2013

**Omnik New Energy Co., Ltd** here by confirms that the product lines:

**Omniksol-1K-TL2-M**

**Omniksol-1.5K-TL2-M**

Are in conformity with the EN50438:2013 Requirement and contain "Irish Settings" option for the connection of micro-generators in parallel with public low-voltage distribution networks.

The test results are summarized in the **Enclosure 1** of this declaration.

**Omnik New Energy Co., Ltd**

24 Nov 2017

*Chenyang*

Chenyang.Pe  
(Product manger)



**Enclosure 1**  
**Test results sheet**

**Power quality**

Harmonic current emission								
	Maximum permissible harmonic current as per EN61000-3-2 ClassA							
Harmonic	2nd	3rd	5th	7th	9th	11th	13th	15th≤n≤39th
Limit	1.08	2.3	1.14	0.77	0.4	0.33	0.21	0.15 <sup>a)</sup> (15/n)
Test value	0.015	0.081	0.033	0.029	0.004	0.036	0.01	<limit of EN 61000-3-2

a)50% or some other declared value close to the midpoint between minimum and maximum.

Voltage fluctuations and flicker				
	Maximum permissible voltage fluctuation(express as a percentage of nominal voltage at 100% power) and flicker as per EN 61000-3-3			
	Starting	Stopping	Running	
Limit	3.3%	3.3%	Pst=1.0	Plt=0.65
Test value	<3.3%	<3.3%	0.17	0.15

Power factor			
Protection limit	+0.95-0.95 at three voltage levels		
	210V	230V	250V
Test value	0.9998	0.9996	0.9998



**Grid monitoring**  
**Under/ Over frequency**

Parameter	Under frequency		Over frequency	
	Frequency	Time	Frequency	Time
Protection limit (EN 50438 Annex A)	48Hz	0.5s	50.5Hz	0.5s
Actual setting	48Hz	0.5s	50.5Hz	0.5s
Trip value (test result)	48.01Hz	0.402s	50.49Hz	0.393s

**Under / Over voltage**

Parameter	Under frequency		Over frequency	
	Voltage	Time	Voltage	Time
Protection limit (EN 50438 Annex A)	230V-10%	0.5s	230V+10%	0.5s
Actual setting	207.0V	0.5s	253.0V	0.5s
Trip value(test result)	207.1V	0.399s	252.9V	0.416s

**LoM**

Output power level a)	Min.	Medium	Max.
Trip setting clearance time	0.5s	0.5s	0.5s
Trip value clearance time	0.125s	0.136s	0.128s

a) Indicative values are shown for minimum, medium and maximum power levels.

**Fault level contribution**

<b>Short-circuit current at micro-generator terminals</b>
0.0150kA

