



太阳能产品认证证书

证书编号：CQC18024188141

申请人名称及地址

苏州欧姆尼克新能源科技有限公司
苏州工业园区唯新路63号

制造商名称及地址

苏州欧姆尼克新能源科技有限公司
苏州工业园区唯新路63号

生产企业名称及地址

上能电气股份有限公司(V023996)
无锡市惠山区和惠路6号

产品名称和系列、规格、型号

光伏并网逆变器

Omniksol-50k-TL3、Omniksol-60k-TL3、Omniksol-60k-TL3-H (见附件)

产品标准和技术要求

NB/T32004-2013 (IIIa, 不含低电压穿越试验)

认证模式

产品型式试验+初次工厂检查+获证后监督

上述产品符合 CQC33-461239-2013 认证规则的要求，特发此证。

发证日期：2018年03月13日 有效期至：2023年01月26日

证书有效期内本证书的有效性依据发证机构的定期监督获得保持。



主任：



中国质量认证中心

中国·北京·南四环西路188号9区100070

<http://www.cqc.com.cn>

T 0007361



SOLAR PRODUCT CERTIFICATE

CERTIFICATE NO.: CQC18024188141

NAME AND ADDRESS OF THE APPLICANT

Omnik New Energy Co.,Ltd.
No.63 Weixin Road SIP Suzhou China

NAME AND ADDRESS OF THE MANUFACTURER

Omnik New Energy Co.,Ltd.
No.63 Weixin Road SIP Suzhou China

NAME AND ADDRESS OF THE FACTORY

SINENG ELECTRIC CO.,LTD (V023996)
No.6, Hehui Road, Huishan District, Wuxi, China

PRODUCT NAME, MODEL AND SPECIFICATION

PV Grid-connected Inverter
Omniksol-50k-TL3、Omniksol-60k-TL3、Omniksol-60k-TL3-H(See Appendix)

THE STANDARDS AND TECHNICAL REQUIREMENTS FOR THE PRODUCTS

NB/T32004-2013(IIIa,Without Low Voltage Ride Through Test)

TYPE OF CERTIFICATION SCHEMES

Type Testing of Product + Initial Factory Inspection + Follow up Factory Inspection

This is to certify that the above mentioned product(s) complies with the requirements of certification rules of CQC33-461239-2013 .

Valid from: Mar.13,2018

Valid until: Jan.26,2023

The validity of the certificate is subject to positive result of the regular follow up inspection by issuing certification body until the expiry date.



President: _____

Wang Kejiao



CHINA QUALITY CERTIFICATION CENTRE

Section 9, No.188, Nansihuan Xilu, Beijing 100070 P.R.China

<http://www.cqc.com.cn>

T 0007361



太阳能产品认证证书

附 录

第 1 页 共 1 页

证书编号: CQC18024188141

纸 号: 7361

Omniksol-50k-TL3

直流输入: MPPT 电压范围 250Vdc-900Vdc, 最大直流输入电压 1000Vdc,

最大直流输入电流 39A /39A /39A

交流输出: 3/N/PE~400V, 50Hz, 最大交流输出电流 80A, 额定交流输出功率 50kW.

Omniksol-60k-TL3

直流输入: MPPT 电压范围 250Vdc-900Vdc, 最大直流输入电压 1000Vdc,

最大直流输入电流 40 A /40 A /40 A

交流输出: 3/N/PE~400V, 50Hz, 最大交流输出电流 95A, 额定交流输出功率 60kW.

Omniksol-60k-TL3-H

直流输入: MPPT 电压范围 250Vdc-900Vdc, 最大直流输入电压 1000Vdc,

最大直流输入电流 38 A /38 A /38 A

交流输出: 3/PE~480V, 50Hz, 最大交流输出电流 80A, 额定交流输出功率 60kW.

注: 此附录与证书同时使用时有效。



主任: _____

A handwritten signature in black ink, written over a horizontal line.



中国质量认证中心

中国 北京 南四环西路 188 号 9 区 100070

<http://www.cqc.com.cn>